

दूरभाष Phone : 91-481-2353311 to 20 (10 लाइनें Lines)

फैक्स Fax : 91-481-2353121 / 2353324

ई-मेल E-mail: qc@rubberboard.org.in

वेब साइट Website: www.rubberboard.org.in



रबर बोर्ड RUBBER BOARD

(वाणिज्य एवं उद्योग मंत्रालय, भारत सरकार)

(Ministry of Commerce & Industry, Government of India)

ENGINEERING AND PROCESSING DIVISION

केंद्रीय गुणता नियंत्रण प्रयोगशाला

CENTRAL QUALITY CONTROL LABORATORY

रबर बोर्ड पी.ओ., कोट्टयम - 686 009 Rubber Board P.O., Kottayam - 686 009

केरल, भारत Kerala, India

TEST CERTIFICATE

Sree Rajahamsa Asramama Vidyapeedom

Champakara

Asramampadi

Karukachal

srajahamsa2021@gmail.com

Certificate No : 2590/W-1/23

Date of issue : 30.08.2023

Customer Ref. & date : nil

Date of sample receipt : 02.08.2023

Date of Completion : 23.08.2023

Sample Name : WATER

RESULT OF ANALYSIS:

Sl No	Parameter	unit	Value	Permissible Limit
1	pH		7.0	6.5 - 8.5
2	Colour	Colourless	Colourless
3	Turbidity	NTU	0	1
4	Fluoride	mg/ litre	Trace	1.0
5	Odour	Odourless	Not Objectionable
6	Total Dissolved Solids	mg/ litre	106	500 (maximum)
7	Total Hardness	mg/ litre	63.7	300 (maximum)
8	Dissolved Oxygen	mg/ litre	5.9
9	Total Iron as Fe	mg/ litre	0.10	0.30 (maximum)
10	Nitrate	mg/ litre	Trace	45 (maximum)
11	Sulphate	mg/ litre	Trace	200 (maximum)
12	Chloride	mg/ litre	Trace	250 (maximum)
13	Coliforms	Present	Absent
14	E Coli	Present	Absent
15	MPN/100	23	Absent

Remarks

